

कार्यालय जिला जल परीक्षण प्रयोगशाला
लोक स्वास्थ्य यांत्रिकी विभाग
शिवपुरी मध्य प्रदेश

क्र. 06 / 2025

दिनांक 19 / 06 / 2025

It is certified that an inspection team headed by Mr. Rajeev Bhatia Lab Incharge from Shivpuri Madhya Pradesh PHED. Inspected the Saraswati Vidyapeeth Awaseey Vidyalaya Shivpuri on 18/06/2025 and on the basis of Water Test Report (Attached) bearing no. 81/1 Dated 19/06/2025 of PHED Lab Shivpuri Madhya Pradesh certified that the Saraswati Vidyapeeth Awaseey Vidyalaya Shivpuri has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the State Govt. of Madhya Pradesh.

This certificate is valid till 17/06/2026

Signature with Seal

Name

Designation

PHE Water Testing Lab Dist. Shivpuri M.P.

DR dis
19/06/25

Rajeev Bhatia

Quality manager

D.W.T.L Shivpuri

To,

Saraswati Vidyapeeth Awaseey Vidyalaya Shivpuri

Fatehpur road, ward no. 15 Shivpuri Madhya Pradesh

प्रमुख
संस्थापक
सरस्वती विद्यापीठ आवासीय विद्यालय
शिवपुरी (म.प्र.)

प्रचार्य
सरस्वती विद्यापीठ उ.मा. विद्यालय
शिवपुरी (म.प्र.) कोड 162025

Status of Sample	Chemical /Bacteriological Test	Unique Identification No.	81/1	7
Sender's name	By- Saraswati Vidhyapeeth Awaseey Vidyalaya Shivpuri	Sender's letter no.	1039	
Sender's address	By- Saraswati Vidhyapeeth Awaseey Vidyalaya Shivpuri	Sender's letter date	17/06/2025	0
		Start Date Of Analysis	18/06/2025	0
Quantity of Sample	1 Ltr.	Receipt No.	03	
Sample Collected by	School Staff	End Date Of Analysis	19/06/2025	0

Sample details:

S.No	Distt	Block	Village	Location	source
1	Shivpuri	Shivpuri	Shivpuri	Saraswati Vidhyapeeth Awaseey Vidyalaya Shivpuri Fatehpur road. ward no. 15 Shivpuri	B W

Physical/ Chemical /Bacteriological Test Report With Details of Parameters Their Test Methods, Units and Specifications as per BIS.

S. No	Characteristics	Test Method (BIS 10500:2012)	Unit	As per BIS- 10500:2012 & Reaffirmed in Sep. 2018		Test Result						
				Require ment (Desirab le Limit)	Permissib le Limit in the absence of Alternate Source	Sample Numbers						
						1	2	3	4	5	6	7
	2	3	4	5	6	7						
1	Turbidity	BIS :3025 Part 10	NTU	1	5	3.0	-	-	-	-	-	-
2	pH	BIS :3025 Part 11	pH scale	6.5to8. 5	<6.5to9. 2>	7.0	-	-	-	-	-	-
3	TDS	BIS :3025 Part 16		500	2000	205	-	-	-	-	-	-
4	Total Hardness as CaCO ₃	BIS :3025 Part 21	mg/l	200	600	294	-	-	-	-	-	-
5	Total Alkalinity as CaCO ₃	BIS :3025 Part 23	mg/l	200	600	216	-	-	-	-	-	-
6	Residual chlorine	BIS :3025 Part 26	ppm	0.2	>1.0	Nil	-	-	-	-	-	-
7	Chloride as Cl	BIS :3025 Part 32	mg/l	250	1000	75	-	-	-	-	-	-
8	Calcium as Ca ⁺⁺	BIS :3025 Part 40	mg/l	75	200	90	-	-	-	-	-	-
9	Magnesium as Mg	BIS :3025 Part 46	mg/l	30	100	16	-	-	-	-	-	-
10	Iron as Fe ⁺⁺	BIS :3025 Part 53	mg/l	0.3	1.0	0.1	-	-	-	-	-	-
11	Nitrate as NO ₃	BIS :3025 Part 34	mg/l	45	45	05	-	-	-	-	-	-
12	Fluoride as F ⁻	BIS :3025 Part 60	mg/l	1.0	1.5	0.04	-	-	-	-	-	-
13	Total coliform MPN/100ml	standard method1992	MPN 100ml	zero	10	0	-	-	-	-	-	-



Signature

Authorized Signatory

Quality manager
D.W.T.L. shivpuri
(M.P.)



सहसंचालक
सरस्वती विद्यापीठ आवासीय विद्यालय
शिवपुरी (म.प्र.)



प्रधान
सरस्वती विद्यापीठ उ.मा. विद्यालय
शिवपुरी (म.प्र.) कोड 462025